

NFRC Product Certification Authorization Report



IA: Keystone Certifications, Inc.

Manufacturer: Matthews Millwork, Inc. dba
 ThermoBuilt Access Doors
Product Series: ThermoBuilt Access Door
Simulation Lab: SEEL
Test Date: 1/12/2007
Revised Date: 1/12/2007
Air Leakage:

Street: 1415 N. Charlotte Avenue
City/State/Zip: Monroe, NC 28110

Type: Swinging Door
Simulation Report Date: 2/5/2007
Initial Certification Date: 10/2/2002
Expiration Date: 1/12/2011

CPD Number: MAT-K-1
Simulation Report Number: MMI701w
Re-Certification Date: 3/30/2007
Print Date: 03/30/2007

Status	Prod. Num.	Mfr. Code	Frames/Sash	Glas. Layers	Low-E (Surfaces)	Gap Width(s)	Spacer	Cap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Condens. Resist.
	00003		ThermoBuilt Access Door	1			N		N			0.20	0.01		0.00

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TAIR	1/12/2007	37.64 X 81.65	0.23	0.22	NV-00755 Rev1

Comments:
Basement access door. Never glazed.

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Digitally signed by Jennifer Heitzemater
 Reason: I attest to the accuracy and integrity of this document
 Date: 2007.03.30 11:57:51 -04'00'

Jennifer Heitzemater

Authorized IA Signature: